

R1 Type	Performance Parameter	conversion factor	GJ	
Ep	Electrical Power Production	181,688.3 MWh/a	2.600	1,700,602
Ep	Heat (Commercial Use)	75,429.2 MWh/a	1.100	298,700
Ep	Heat (Own Use, not included)	103,471.8 MWh/a	1.100	409,748
	auxiliary fuel (oil)	19,418.3 MWh/a		
Ep	condensate return	6,233.9 MWh/a	-1.100	-24,686
Ef	Oil with heat recovery	9,709.1 MWh/a	1.000	34,953
Ei	Oil without heat recovery (shutdown, etc)	9,709.1 MWh/a	1.000	34,953
Ei	Parasitic Load during shutdown	350.4 MWh/a	2.600	3,280
Ew	Energy Input Waste	233,019.5 t/a	10.000 GJ/Mg	2,330,195

$\eta = (Ep - (Ef - Ei)) / (0,97 * (Ew + Ef))$ 1.01

Year	8,760 h/a
Operational hours	7,884 h/a
Auxiliary Fuel as Waste Input	3.00% -

R1 treshold
 (plant commissioned after 31.12.2008) 0.65 -

LCV	10.04 GJ/Mg
HCV	11.54 GJ/Mg
Biodegradable fraction	50% -

reference plant from ISDS2 submission

thermal load (LCV)	82.1 MW	82.1
thermal load (HCV)	94.4 MW	
lower caloric value	10.0 GJ/Mg	10
gross electric efficiency	30.4% -	30.4%
availability	90.0% -	90.0%

gross electrical production (max. no heat)	196,772 MWh/a	
throughput	233,020 t/a	
energy input (LCV)	647,276 MWh/a	
energy input (HCV)	743,981 MWh/a	
boiler efficiency	91.8% -	91.8%
	0.905	

Own Use		
air pre-heating register 3	1.850 t/h	1.850
deaerator heating	3.870 t/h	3.870
air pre-heating register 2	3.610 t/h	3.610
air pre-heating register 1	2.170 t/h	2.170
condensate pre-heating	9.100 t/h	9.100
		correction factor own
		100.0%

commercial use	75,429 MWh/a
use of heat system	4,482 h/a
average steam demand	21.289 t/h
max steam capacity	40.000 t/h
(average steam demand reverse calculation)	10.000 t/h
(average steam demand reverse calculation)	35,431 MWh/a

turbine step efficiency	95.5%	-
generator efficiency	99.0%	-
parasitic load factor	10.0%	-
Enthalpy		
steam production	3224.69	kJ/kg 61bar(a), 420°C
boiler hot water	622.13	kJ/kg 81bar(a), 145°C
turbine extraction 1	2845.86	kJ/kg 9bar(a), 198°C
turbine extraction 2	2747.92	kJ/kg 5,5bar(a), 155°C
turbine extraction 3	2509.68	kJ/kg 0,9bar(a), 96°C (x=9%)
turbine exit steam	2571.8	kJ/kg 0,07bar(a), 39°C
turbine exit water	163.4	kJ/kg 0,07bar(a), 39°C
turbine water fraction	14%	-
turbine exit condensate	2234.624	kJ/kg
	336	kJ/kg
steam production boiler	104.253	t/h
power production (reverse efficiency)	24.96	MW el.
power production (no steam)	24.99	MW el.
power loss	3.4	MW el.
gross production	21.6	MW el.
net production	19.1	MW el.
parasitic load	2.5	MW el.
parasitic load during shut down	0.4	MW el.
Max Heat operation		
power loss (maxheat)	6.4	MW el.
gross production (maxheat)	18.6	MW el.
net production (maxheat)	16.1	MW el.
High steam demand		
	15%	-
power loss	3.9	MW el.
gross production	21.1	MW el.
net production	18.6	MW el.
Low steam demand		
power loss	2.9	MW el.
gross production	22.1	MW el.
net production	19.6	MW el.
own use heat		
air pre-heating register 2	11,530	MWh/a
deaerator heating	24,120	MWh/a
air pre-heating register 1	13,059	MWh/a
condensate pre-heating	54,763	MWh/a
commercial use heat	75,429	MWh/a
energy input waste		
energy input fossil fuel	647,276	MWh/a
power import	19,418	MWh/a
condensate return	350	MWh/a
	6,234	MWh/a
gross production max		
power loss	197,005	MWh/a
gross production	15,317	MWh/a
net production	181,688	MWh/a
parasitic load	161,988	MWh/a
	19,701	MWh/a

ROC Calculation	
CHP TPO	24.99 %
QI X	370 -
QI Y	140 -
QI Z Factor	5.7
eta power	24.42% -
eta heat	10.14% -
QI	104.55 -
delta eta heat	0.00% -
new eta heat	10.14% -
delta eta power	0.00% -
new eta power	24.42% -
new heat / power	41.52% -
CHP QPO	181,688 MWh/a
ROC	80,994 -
LEC Calculation	
Renewable LEC	90,844 -
CHP TPO	24.99 -
QI X	370 -
QI Y	120 -
QI Z Factor	5.7 -
eta power	24.42% -
eta heat	10.14% -
QI	102.52
delta eta heat	0.00% -
new eta heat	10.14% -
delta eta power	0.00% -
new eta power	24.42% -
new heat / power	41.52% -
CHP QPO	181,688 MWh/a
CHP LEC	181,688 -
LEC Total	181,688 -

Commercial DRDL	
Electrical Power Demand	163,000 MWh/a
Gas Demand	88,180 MWh Hs/a
Gas Demand Scaling Factor	100% -
Steam Demand	75,429 MWh/a
Gas Boiler Efficiency	94% -
Gas Factor Hi / Hs	0.91 -
Average Electrical Demand	18.61 MW
Deviation of Electrical Demand	15% -
Average Gas Demand	19.67 MW
Average Steam Demand	16.05 MW
Average Steam Demand	20.30 t/h
Use of Heat System DRDL	4700 h/a
Use of heat System from EfW	4482 h/a
Steam Supply EfW	75,429 MWh/a
Steam Supply Babcock	0 MWh/a
Gas supply backup	0 MWh Hs/a
Gas supply Scaling Factor	100% -
DRDL El. Power Supply EfW	141,486 MWh/a
DRDL El. Power Supply Import Grid	21,514 MWh/a
EfW El. Power Export	20,502 MWh/a
EfW Parasitic Load Produced	19,701 MWh/a
EfW Parasitic Load Import Grid	718 MWh/a
Total Import from Grid	22,232 MWh/a
Total Export to Grid	20,502 MWh/a
Control Net Production	WAHR

R1 Type	Performance Parameter	conversion factor	GJ	
Ep	Electrical Power Production	197,005.2 MWh/a	2.600	1,843,969
Ep	Heat (Commercial Use)	0.0 MWh/a	1.100	0
Ep	Heat (Own Use, not included)	103,471.8 MWh/a	1.100	409,748
	auxiliary fuel (oil)	19,418.3 MWh/a		
Ep	condensate return	0.0 MWh/a	-1.100	0
Ef	Oil with heat recovery	9,709.1 MWh/a	1.000	34,953
Ei	Oil without heat recovery (shutdown, etc)	9,709.1 MWh/a	1.000	34,953
Ei	Parasitic Load during shutdown	350.4 MWh/a	2.600	3,280
Ew	Energy Input Waste	233,019.5 t/a	10.000 GJ/Mg	2,330,195

$\eta = (Ep - (Ef - Ei)) / (0,97 * (Ew + Ef))$ 0.95

Year	8,760 h/a
Operational hours	7,884 h/a
Auxiliary Fuel as Waste Input	3.00% -

R1 threshold
(plant commissioned after 31.12.2008) 0.65 -

LCV	10.04 GJ/Mg
HCV	11.54 GJ/Mg
Biodegradable fraction	50% -

reference plant from ISDS2 submission

thermal load (LCV)	82.1 MW	82.1
thermal load (HCV)	94.4 MW	
lower caloric value	10.0 GJ/Mg	10
gross electric efficiency	30.4% -	30.4%
availability	90.0% -	90.0%

gross electrical production (max. no heat)	196,772 MWh/a	
throughput	233,020 t/a	
energy input (LCV)	647,276 MWh/a	
energy input (HCV)	743,981 MWh/a	
boiler efficiency	91.8% -	91.8%
	0.905	

Own Use		
air pre-heating register 3	1.850 t/h	1.850
deaerator heating	3.870 t/h	3.870
air pre-heating register 2	3.610 t/h	3.610
air pre-heating register 1	2.170 t/h	2.170
condensate pre-heating	9.100 t/h	9.100
		correction factor own
		100.0%

commercial use	0 MWh/a
use of heat system	4,482 h/a
average steam demand	0.000 t/h
max steam capacity	40.000 t/h
(average steam demand reverse calculation)	10.000 t/h
(average steam demand reverse calculation)	35,431 MWh/a

turbine step efficiency	95.5% -
generator efficiency	99.0% -
parasitic load factor	10.0% -

Enthalpy		
steam production	3224.69 kJ/kg	61bar(a), 420°C
boiler hot water	622.13 kJ/kg	81bar(a), 145°C
turbine extraction 1	2845.86 kJ/kg	9bar(a), 198°C
turbine extraction 2	2747.92 kJ/kg	5,5bar(a), 155°C
turbine extraction 3	2509.68 kJ/kg	0,9bar(a), 96°C (x=9%)
turbine exit steam	2571.8 kJ/kg	0,07bar(a), 39°C
turbine exit water	163.4 kJ/kg	0,07bar(a), 39°C
turbine water fraction	14% -	
turbine exit	2234.624 kJ/kg	
condensate	336 kJ/kg	
steam production boiler	104.253 t/h	
power production (reverse efficiency)	24.96 MW el.	
power production (no steam)	24.99 MW el.	
power loss	0.0 MW el.	
gross production	25.0 MW el.	
net production	22.5 MW el.	
parasitic load	2.5 MW el.	
parasitic load during shut down	0.4 MW el.	
Max Heat operation		
power loss (maxheat)	6.4 MW el.	
gross production (maxheat)	18.6 MW el.	
net production (maxheat)	16.1 MW el.	
High steam demand	15% -	
power loss	0.0 MW el.	
gross production	25.0 MW el.	
net production	22.5 MW el.	
Low steam demand		
power loss	0.0 MW el.	
gross production	25.0 MW el.	
net production	22.5 MW el.	
own use heat		
air pre-heating register 2	11,530 MWh/a	
deaerator heating	24,120 MWh/a	
air pre-heating register 1	13,059 MWh/a	
condensate pre-heating	54,763 MWh/a	
commercial use heat	0 MWh/a	
energy input waste	647,276 MWh/a	
energy input fossil fuel	19,418 MWh/a	
power import	350 MWh/a	
condensate return	0 MWh/a	
gross production max	197,005 MWh/a	
power loss	0 MWh/a	
gross production	197,005 MWh/a	
net production	177,305 MWh/a	
parasitic load	19,701 MWh/a	
ROC Calculation		
CHP TPO	24.99 %	
QI X	370 -	
QI Y	140 -	
QI Z Factor	5.7	
eta power	26.48% -	
eta heat	0.00% -	
QI	97.98 -	
delta eta heat	2.70% -	

APDX 3.3_5

R1 model

Scenario 2 - No steam

new eta heat	2.70% -
delta eta power	0.47% -
new eta power	26.95% -
new heat / power	10.00% -
CHP QPO	0 MWh/a
ROC	0 -
LEC Calculation	
Renewable LEC	98,503 -
CHP TPO	24.99 -
QI X	370 -
QI Y	120 -
QI Z Factor	5.7 -
eta power	26.48% -
eta heat	0.00% -
QI	97.98
delta eta heat	3.67% -
new eta heat	3.67% -
delta eta power	0.64% -
new eta power	27.12% -
new heat / power	13.55% -
CHP QPO	0 MWh/a
CHP LEC	0 -
LEC Total	98,503 -
Commercial DRDL	
Electrical Power Demand	163,000 MWh/a
Gas Demand	0 MWh Hs/a
Gas Demand Scaling Factor	100% -
Steam Demand	0 MWh/a
Gas Boiler Efficiency	94% -
Gas Factor Hi / Hs	0.91 -
Average Electrical Demand	18.61 MW
Deviation of Electrical Demand	15% -
Average Gas Demand	0.00 MW
Average Steam Demand	0.00 MW
Average Steam Demand	0.00 t/h
Use of Heat System DRDL	4700 h/a
Use of heat System from EfW	4482 h/a
Steam Supply EfW	0 MWh/a
Steam Supply Babcock	0 MWh/a
Gas supply backup	0 MWh Hs/a
Gas supply Scaling Factor	100% -
DRDL El. Power Supply EfW	146,700 MWh/a
DRDL El. Power Supply Import Grid	16,300 MWh/a
EfW El. Power Export	30,605 MWh/a
EfW Parasitic Load Produced	19,701 MWh/a
EfW Parasitic Load Import Grid	718 MWh/a
Total Import from Grid	17,018 MWh/a
Total Export to Grid	30,605 MWh/a
Control Net Production	WAHR