

Notification of breach of noise limits
Devonport EfW CHP facility
11/00750/FUL

Notice is hereby given of an exceedance of noise limits.

Below is a table of actions as described in point 4.4 of the Noise Management Plan:

Date:	28/11/12
Time:	08:53 – 11:54
Receptor:	R3 (Savage Road)
Measured L_{Aeq} (30 minute indication):	71dB
Identified source:	Piling rig clearing obstructions in the ground
Mitigation measure(s):	Rig stopped and additional acoustic barriers placed around it
Post-mitigation L_{Aeq} (2 hour monitoring):	67dB
Time of post-mitigation monitoring:	09:54 – 11:54
Further mitigation:	Obstructions had been cleared with a noticeable reduction in noise levels so none was considered necessary
Further monitoring L_{Aeq}:	64dB
Time of further monitoring:	Two hours between 12:40 – 15:34 (12:40 – 13:10 and 14:03 – 15:34)