

Table 1 Construction Noise Levels: Initial 30 Minute Readings

Location	Date	Estimated LAeq 10hr dB (facade)	Maximum Permitted Noise Level (LAeq 10hr dB)	Difference (dB)
Talbot Gardens (R17)	13/08/2012	67	70	-3
	14/08/2012	67	70	-3
	22/08/2012	64	70	-6
Talbot Gardens (R15)	21/08/2012	64	70	-6
	22/08/2012	67	70	-3
	29/08/2012	64	70	-6
	30/08/2012	62	70	-8
	05/09/2012	64	70	-6
	21/09/2012	65	70	-5
	28/09/2012	60	70	-10
	10/10/2012	69	70	-1
	24/10/2012	62	70	-8
	08/11/2012	64	70	-6
Wolseley Road (R20)	28/11/2012	68	70	-2
	14/08/2012	50	60	-10
	21/08/2012	57	60	-3
	22/08/2012	57	60	-3
	29/08/2012	55	60	-5
	30/08/2012	56	60	-4
	05/09/2012	56	60	-4
HamoazeAve (R22)	21/09/2012	56	60	-4
	14/08/2012	49	57	-8
	21/08/2012	48	57	-9
	22/08/2012	51	57	-6
	29/08/2012	54	57	-3
	30/08/2012	48	57	-9
	05/09/2012	49	57	-8
	21/09/2012	46	57	-11
	24/10/2012	47	57	-10
Savage Road (R3)	09/11/2012	50	57	-7
	28/11/2012	50	57	-7
	13/08/2012	64	65	-1
	14/08/2012	61	65	-4
	21/08/2012	63	66	-3
	22/08/2012	61	66	-5
	29/08/2012	64	66	-2
	30/08/2012	66	66	0
	05/09/2012	64	66	-2
	14/09/2012	62	66	-4
	14/09/2012	64	66	-2
	21/09/2012	64	66	-2
	28/09/2012	67	66	1
	03/10/2012	64	66	-2
10/10/2012	69	66	3	
Cardinal Ave	24/10/2012	66	66	0
	08/11/2012	68	66	2
	28/11/2012	71	66	5
	09/11/2012	60	-	-
	24/10/2012	59	-	-
Cardinal Ave	05/09/2012	57	-	-
	30/08/2012	58	-	-
	09/11/2012	60	-	-