

URS

EfW CHP Facility, Devonport

Non-Destructive Testing
Noise Report

30th January 2014

Prepared for:



UNITED
KINGDOM &
IRELAND



Rev	Date	Details	Prepared by	Checked by	Approved by
0	31.01.14	Final	Daniel Ellis Graduate Environmental Consultant	Alf Maneylaws Associate Noise & Vibration	Ian Roach Associate Environment and Planning

URS Infrastructure & Environment UK Limited
 Mayflower House
 Armada Way
 Plymouth
 PL1 1LD

+44 (0)1752 676 700

Limitations

URS Infrastructure & Environment UK Limited ("URS") has prepared this Report for the sole use of MVV Environment Devonport Limited ("Client") in accordance with the agreed MVV Professional Service Contract dated 28 May 2009, novated to MVV Environment Devonport Ltd 9 May 2011. No other warranty, expressed or implied, is made as to the professional advice included in this Report or any other services provided by URS.

The methodology adopted and the sources of information used by URS in providing its services are outlined in this Report. The work described in this Report was undertaken on 30th January 2014 and is based on the conditions encountered and the information available during the said period of time. The scope of this Report and the services are accordingly factually limited by these circumstances.

URS disclaim any undertaking or obligation to advise any person of any change in any matter affecting the Report, which may come or be brought to URS' attention after the date of the Report.

Certain statements made in the Report that are not historical facts may constitute estimates, projections or other forward looking statements and even though they are based on reasonable assumptions as of the date of the Report, such forward-looking statements by their nature involve risks and uncertainties that could cause actual results to differ materially from the results predicted. URS specifically does not guarantee or warrant any estimate or projections contained in this Report.

Where field investigations are carried out, these have been restricted to a level of detail required to meet the stated objectives of the services.

Copyright

© This Report is the copyright of URS Infrastructure & Environment UK Limited. Any unauthorised reproduction or usage by any person other than the addressee is strictly prohibited.

TABLE OF CONTENTS	EXECUTIVE SUMMARY.....	1
	1. INTRODUCTION.....	2
	1.1 Baseline Noise Limits.....	2
	2. SITE DESCRIPTION.....	3
	3. METHODOLOGY AND ASSESSMENT CRITERIA	3
	4. NON-DESTRUCTIVE TESTING NOISE SURVEY.....	3
	4.1 Protocol.....	3
	4.2 Instrumentation	4
	4.3 Meteorological Conditions.....	4
	4.4 Commentary.....	5
	4.5 Results	5
	APPENDIX A: FULL NOISE MONITORING RESULTS.....	

EXECUTIVE SUMMARY

On Wednesday 30th January 2014 noise monitoring was undertaken for MVV Environment Devonport Ltd (MVV) at three sensitive residential receptors close to the site boundary, to determine the noise levels during Non-Destructive Testing (NDT).

The following noise levels were recorded:

- At R3 (Savage Road): 54 dB $L_{Aeq,35min}$ (façade): 3 dB above the baseline;
- At R15 (Talbot Gardens): 45 dB $L_{Aeq,50min}$ (façade): 2 dB above the baseline; and
- At Cardinal Ave: 46 dB $L_{Aeq,50min}$ (free-field)/ 49 dB $L_{Aeq,50min}$ (façade): 2 dB below the baseline.

Noise levels recorded were within the Plymouth City Council's Code of Construction Practice noise limits for weekday evening work and within 5dB of the baseline noise level.

Noise was dominated by road traffic. No site noise was noticeable at Cardinal Ave and the only minor site noise was recorded at Savage Road and Talbot Gardens – this was noted as not being louder than other background noises, and potentially unnoticeable to those unaware that NDT was occurring.

1. INTRODUCTION

MVV Environment Devonport Ltd (MVV) undertook Non-Destructive Testing (NDT) outside usual working hours on Thursday 30th January 2014, between 18:00 and 21:00. MVV commissioned URS to undertake noise monitoring at three sensitive residential receptors close to the site boundary.

This report describes the methodology and findings of the noise survey undertaken on this day.

1.1 Baseline Noise Limits

Baseline noise levels were monitored prior to NDT works commencing; with noise limits set based on Plymouth City Council’s Code of Construction Practice. Table 1 shows baseline noise levels and the noise limits.

TABLE 1: BASELINE NOISE LEVELS AND NOISE LIMITS FOR NDT					
Location	Time	Ambient L _{Aeq,4hr} (dB)		Noise Limits (based on façade measurement)	
		Free Field	Façade	L _{Aeq,4hr} *1 dB	L _{Aeq,1hr} dB
R3 (Savage Road)	Weekend	-	54	64	67
	Weekday	-	51	61	64
R15 (Talbot Gardens)	Weekend	-	45	60	63
	Weekday	-	43	58	61
Cardinal Ave	Weekend	51	54	64	67
	Weekday	48	51	61	64

*1 The L_{Aeq,4hr} noise limit shall be applied to all noise measurements of NDT

2. SITE DESCRIPTION

The EfW CHP facility is currently being constructed in the North Yard of Her Majesty’s Naval Base (HMNB), beside Camels Head junction (the junction between the A3064 and Wolseley Road). The development is located close to a number of residential properties, most noticeably those in Barne Barton to the north of the site, as well as on Cardinal Ave to the north-east.

3. METHODOLOGY AND ASSESSMENT CRITERIA

The monitoring procedure conformed to BS 7445: 2003 ‘Description and Measurement of Environmental Noise’, with measurements at Savage Road and Talbot Gardens taken 1 metre from the façade of residential receptors at a height of 1.5 metres. At Cardinal Ave, the measurement was taken free-field, over 3.5 metres from the façade. Average wind speeds were below 5 ms⁻¹.

4. NON-DESTRUCTIVE TESTING NOISE SURVEY

4.1 Protocol

Due to the lack of secure monitoring locations, it was not possible to leave equipment unattended. Consequently, manned noise monitoring has been undertaken.

Monitoring was undertaken for a 50 minute period at each of the three locations representative of the closest receptors to the site. The measurements at the three locations were carried out consecutively, therefore covering the whole period of NDT works occurring on site; logging L_{Aeq} and L_{AFmax} levels in contiguous 5-minute periods.

Table 1 lists the noise monitoring locations as well as the time monitoring was undertaken.

TABLE 2: NOISE MONITORING LOCATION AND TIMINGS				
Location*	Road	Details	Date	Time
R3	Savage Road	Representative of the closest noise sensitive properties to the north west (approx. 100 metres from the Site).	Thursday 30 th January 2014 (weekday)	18:00 – 18:50
R15	Talbot Gardens	Representative of the closest noise sensitive properties to the north (approx. 60 metres from the Site).	Thursday 30 th January 2014 (weekday)	19:00 – 19:50
-	Cardinal Ave	Representative of the closest noise sensitive properties to the north-east (approx. 200 metres from the Site).	Thursday 30 th January 2014 (weekday)	20:00 – 20:50

* Correlates with residential receptors for the Environmental Statement for the EfW CHP facility (11/00750/FUL)

4.2 Instrumentation

The sound level meter utilised for the monitoring:

- A B&K 2238 sound level meter, serial number 2562627 was used

Full calibration details are available upon request.

The calibration levels were checked prior to and following the measurements with a:

- B&K 4231 field calibrator, serial number 2217876 and no significant drift was noted (+/- 0.2 dB).

4.3 Meteorological Conditions

Weather conditions during the measurements were as shown below in Table 3.

TABLE 3: WEATHER CONDITIONS DURING NOISE MONITORING					
Location	Date/Time	Max Wind Speed (m/s)	Wind Direction	Temperature	Precipitation
R3	30/01/2014 18:00 – 18:50	0.3	E	5°C	None
R15	30/01/2014 19:00 – 19:50	0.3	E	4°C	None
Cardinal Ave	30/01/2014 20:00 – 20:50	0.3	E	4°C	None

4.4 Commentary

The following observations of local noise sources were made whilst at the site during monitoring:

- At R3 (Savage Road) the noise climate was dominated by local road traffic noise on Savage Road (vehicles and motorbikes) and other surrounding roads (particularly Wolseley Road). There was also noise from loudspeaker announcements in HMNB; and passing trains. In addition, there was also noise from residents and pedestrians parking up and/or walking past; as well as noise from within a residential property close to the SLM. A number of light clangs were noted by the surveyor, which were presumed to originate from site, as well as other quiet unidentified noises, presumed to be noise from NDT operatives moving around within the building. It was noted that this site noise was not louder than other background noise, and potentially unnoticeable to those unaware that NDT was occurring.
- At R15 (Talbot Gardens) the noise climate was dominated by a range of noise from HMNB. Noises from HMNB were varied and included: loudspeaker announcements, noise from the sports pitch, and an unidentified hum. In addition, there was also noise from road traffic from surrounding roads (particularly Savage Road and Wolseley Road); passing trains; and occasional noise from vehicles and pedestrians passing on Talbot Gardens. A number of light clangs were noted by the surveyor, which were presumed to originate from site. It was noted that this site noise was not louder than other background noise, and potentially unnoticeable to those unaware that NDT was occurring.
- At Cardinal Ave the noise climate was dominated by a mixture of noise from: road traffic on Cardinal Ave (cars manoeuvring, parking and passing etc...); as well as from surrounding roads (particularly Wolseley Road); and passing trains. Also there was occasional noise from pedestrians and residents walking past the SLM, and from within residential properties. No site noise was noticeable at Cardinal Ave.

4.5 Results

The results of noise monitoring undertaken on 30th January 2014 are given below in Table 4.

The full noise survey data for all three sites are provided in Appendix A, Tables A1 to A3.

TABLE 4: BASELINE NOISE LEVELS AND NOISE LIMITS FOR NDT

Location	Date & Time	NDT Noise Level L _{Aeq,50min} (dB)		NDT Noise Level L _{AFmax} (dB)	Baseline Noise Level L _{Aeq,4hr} (dB)		Noise Limits (based on façade measurement)	Difference between NDT Noise Level (L _{Aeq,50min}) and Baseline (L _{Aeq,4hr}) (dB)
		Free Field	Façade	Façade	Free Field	Façade	L _{Aeq,4hr} dB	
R3	30/01/2014 18:00 – 18:50	-	54	72	-	51	61	3
R15	30/01/2014 19:00 – 19:50	-	45	65	-	43	58	2
Cardinal Ave	30/01/2014 20:00 – 20:50	46	49	72	48	51	61	-2

The recorded noise levels at all three receptors were below the adopted noise limits and within 5dB of the baseline level. In particular the noise level at Cardinal Ave was 2 dB below the baseline. The surveyor noted there was minimal road traffic during the monitoring period at Cardinal Ave, which is likely to account for the lower noise levels. The L_{AFmax} events included in Table 4 were not a result of NDT testing, but instead due to off-site noises.

It was noted by the surveyor that NDT works were not the dominant noise source at any location; in particular at Cardinal Ave no NDT works noise was picked up by the surveyor. All site noise from Savage Road and Talbot Gardens was recorded by the surveyor and included in Appendix A, Table A1 and A2. The noise was not intrusive and unlikely to be heard by residents.

It was noted by surveyors that if residents were unaware of NDT occurring, they would unlikely have noticed these minor site noises.

APPENDIX A: FULL NOISE MONITORING RESULTS

Tables A1 to A3 list the full suite of measured noise data.

TABLE A1: SAVAGE ROAD MEASURED NOISE LEVELS					
Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
30/01/2014 18:00	05:00.0	56.2	71.8	50	Distant siren getting closer through recording; Loudspeaker announcement in HMNB; Train.
30/01/2014 18:05	05:00.0	54.7	68.1	49.5	Ambulance passing below SLM (no siren); Residents talking outside; Clang on site; Two motorbikes passing; Dog barking in residential property close to SLM.
30/01/2014 18:10	05:00.0	54.5	67.2	49.5	Resident passing; Clang on site; Train.
30/01/2014 18:15	05:00.0	53.8	64.1	49.5	Loudspeaker announcement in HMNB with screeching electrical feedback noise; Noise from operatives walking around within the building.
30/01/2014 18:20	05:00.0	55	66	49.5	Clang on site; Loudspeaker announcement in HMNB with screeching electrical feedback noise; Plane overhead; Pedestrians further down Savage Road talking loudly.
30/01/2014 18:25	05:00.0	54.6	65.8	49	Resident passing SLM; Train; Loudspeaker announcement in HMNB with screeching electrical feedback noise.
30/01/2014 18:30	05:00.0	52	67.8	49.5	Clang on site; Train; Car pulls up below SLM; Raised voices in residential property close to SLM.
30/01/2014 18:35	05:00.0	53.7	65.5	49	Loudspeaker announcement in HMNB; Car pulls away below SLM; Pedestrian passing below SLM talking on mobile; Raised voices in residential property close to SLM; Train.

TABLE A1: SAVAGE ROAD MEASURED NOISE LEVELS

Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
30/01/2014 18:40	05:00.0	54.1	68.3	48.5	Loudspeaker announcement in HMNB; Car with loud exhaust passing.
30/01/2014 18:45	05:00.0	53.8	64.7	49.5	Pedestrian passing below SLM, with crying child.

TABLE A2: TALBOT GARDENS MEASURED NOISE LEVELS

Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
30/01/2014 19:00	05:00.0	45.3	55	42.5	Train.
30/01/2014 19:05	05:00.0	44.9	56.6	43	Loudspeaker announcement in HMNB.
30/01/2014 19:10	05:00.0	44	52.9	42.5	
30/01/2014 19:15	05:00.0	45.6	54.3	42.5	Loudspeaker announcements in HMNB with screeching electrical feedback noise; Train; Clang on site.
30/01/2014 19:20	05:00.0	44.1	52	42	Vehicle on Talbot Gardens; Clang on site.
30/01/2014 19:25	05:00.0	42.8	48.1	41.5	Unidentified noise on site.
30/01/2014 19:30	05:00.0	43.3	55.5	41.5	Loudspeaker announcement in HMNB.
30/01/2014 19:35	05:00.0	49.1	58.9	41.5	Train.
30/01/2014 19:40	05:00.0	43.4	65	41.5	
30/01/2014 19:45	05:00.0	43.3	51.5	41.5	Clang on site.

TABLE A3: CARDINAL AVENUE MEASURED NOISE LEVELS

Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
30/01/2014 20:00	05:00.0	43.5	63.1	41	Car pulling up close to SLM.
30/01/2014 20:05	05:00.0	44.1	53.2	41.5	Pedestrian walking past; Train.
30/01/2014 20:10	05:00.0	42.3	46.5	40.5	
30/01/2014 20:15	05:00.0	43	51	41	Children walking past talking.
30/01/2014 20:20	05:00.0	46.9	65.2	40.5	
30/01/2014 20:25	05:00.0	42.7	55.3	41	
30/01/2014 20:30	05:00.0	48.2	65.5	40.5	Train; Children walking past talking.
30/01/2014 20:35	05:00.0	42.6	56.2	41	
30/01/2014 20:40	05:00.0	50	68.9	41	Car passing and hitting kerb one metre from SLM.
30/01/2014 20:45	05:00.0	45	59.6	41.5	