



EfW CHP Facility, Devonport

Non-Destructive Testing
Noise Report

13th June 2014

Prepared for:



UNITED
KINGDOM &
IRELAND



Rev	Date	Details	Prepared by	Checked by	Approved by
0	13.06.14	Final	Daniel Ellis Graduate Environmental Consultant	Alf Maneylaws Associate Noise & Vibration	Ian Roach Associate Environment and Planning

URS Infrastructure & Environment UK Limited
Mayflower House
Armada Way
Plymouth
PL1 1LD

+44 (0)1752 676 700

Limitations

URS Infrastructure & Environment UK Limited ("URS") has prepared this Report for the sole use of MVV Environment Devonport Limited ("Client") in accordance with the agreed MVV Professional Service Contract dated 28 May 2009, novated to MVV Environment Devonport Ltd 9 May 2011. No other warranty, expressed or implied, is made as to the professional advice included in this Report or any other services provided by URS.

The methodology adopted and the sources of information used by URS in providing its services are outlined in this Report. The work described in this Report was undertaken on 12th June 2014 and is based on the conditions encountered and the information available during the said period of time. The scope of this Report and the services are accordingly factually limited by these circumstances.

URS disclaim any undertaking or obligation to advise any person of any change in any matter affecting the Report, which may come or be brought to URS' attention after the date of the Report.

Certain statements made in the Report that are not historical facts may constitute estimates, projections or other forward looking statements and even though they are based on reasonable assumptions as of the date of the Report, such forward-looking statements by their nature involve risks and uncertainties that could cause actual results to differ materially from the results predicted. URS specifically does not guarantee or warrant any estimate or projections contained in this Report.

Where field investigations are carried out, these have been restricted to a level of detail required to meet the stated objectives of the services.

Copyright

© This Report is the copyright of URS Infrastructure & Environment UK Limited. Any unauthorised reproduction or usage by any person other than the addressee is strictly prohibited.

TABLE OF CONTENTS	EXECUTIVE SUMMARY.....	1
	1. INTRODUCTION.....	2
	1.1 Baseline Noise Limits.....	2
	2. SITE DESCRIPTION.....	2
	3. METHODOLOGY AND ASSESSMENT CRITERIA	2
	4. NON-DESTRUCTIVE TESTING NOISE SURVEY.....	3
	4.1 Protocol.....	3
	4.2 Instrumentation	3
	4.3 Meteorological Conditions.....	4
	4.4 Commentary.....	4
	4.5 Results	4
	APPENDIX A: FULL NOISE MONITORING RESULTS.....	

EXECUTIVE SUMMARY

On Thursday 12th June 2014 noise monitoring was undertaken for MVV Environment Devonport Ltd (MVV) at two sensitive residential receptors close to the site boundary, to determine the noise levels during Non-Destructive Testing (NDT).

The following noise levels were recorded:

- At R3 (Savage Road): 54 dB $L_{Aeq,50min}$ (façade): 3 dB above the baseline; and
- At R15 (Talbot Gardens): 47 dB $L_{Aeq,50min}$ (façade): 4 dB above the baseline.

Noise levels recorded were within the Plymouth City Council's Code of Construction Practice noise limits for weekday evening work and within 5 dB of the baseline noise level. No site noises were recorded at either Savage Road or Talbot Gardens during the monitoring period. Noise was dominated by road traffic and an unidentified hum from Her Majesty's Naval Base.

1. INTRODUCTION

MVV Environment Devonport Ltd (MVV) undertook Non-Destructive Testing (NDT) outside usual working hours on Thursday 12th June 2014, between 18:00 and 22:00. MVV commissioned URS to undertake noise monitoring at two sensitive residential receptors close to the site boundary.

This report describes the methodology and findings of the noise survey undertaken on this day.

1.1 Baseline Noise Limits

Baseline noise levels were monitored prior to NDT works commencing; with noise limits set based on Plymouth City Council's Code of Construction Practice. Table 1 shows baseline noise levels and the noise limits.

TABLE 1: BASELINE NOISE LEVELS AND NOISE LIMITS FOR NDT					
Location	Time	Ambient L _{Aeq,4hr} (dB)		Noise Limits (based on façade measurement)	
		Free Field	Façade	L _{Aeq,4hr} ^{*1} dB	L _{Aeq,1hr} dB
R3 (Savage Road)	Weekend	-	54	64	67
	Weekday	-	51	61	64
R15 (Talbot Gardens)	Weekend	-	45	60	63
	Weekday	-	43	58	61

*1 The L_{Aeq,4hr} noise limit shall be applied to all noise measurements of NDT

2. SITE DESCRIPTION

The EfW CHP facility is currently being constructed in the North Yard of Her Majesty's Naval Base (HMNB), beside Camels Head junction (the junction between the A3064 and Wolseley Road). The development is located close to a number of residential properties, most noticeably those in Barne Barton to the north of the site.

3. METHODOLOGY AND ASSESSMENT CRITERIA

The monitoring procedure conformed to BS 7445: 2003 'Description and Measurement of Environmental Noise', with measurements at Savage Road and Talbot Gardens taken 1 metre from the façade of residential receptors at a height of 1.5 metres. Average wind speeds were below 5 ms⁻¹.

4. NON-DESTRUCTIVE TESTING NOISE SURVEY

4.1 Protocol

Due to the lack of secure monitoring locations, it was not possible to leave equipment unattended. Consequently, manned noise monitoring has been undertaken.

Monitoring was undertaken for a 50 minute period at each of the two locations representative of the closest receptors to the site. The measurements at the two locations were carried out consecutively; logging L_{Aeq} and L_{AFmax} levels in contiguous 5-minute periods.

Table 1 lists the noise monitoring locations as well as the time monitoring was undertaken.

TABLE 2: NOISE MONITORING LOCATION AND TIMINGS				
Location*	Road	Details	Date	Time
R3	Savage Road	Representative of the closest noise sensitive properties to the north west (approx. 100 metres from the Site).	Thursday 12 th June 2014 (weekday)	18:01 – 18:51
R15	Talbot Gardens	Representative of the closest noise sensitive properties to the north (approx. 60 metres from the Site).	Thursday 12 th June 2014 (weekday)	18:56 – 19:46

* Correlates with residential receptors for the Environmental Statement for the EFW CHP facility (11/00750/FUL)

4.2 Instrumentation

The sound level meter utilised for the monitoring:

- A B&K 2238 sound level meter, serial number 2562627 was used

Full calibration details are available upon request.

The calibration levels were checked prior to and following the measurements with a:

- B&K 4231 field calibrator, serial number 2217876 and no significant drift was noted (+/- 0.1 dB).

4.3 Meteorological Conditions

Weather conditions during the measurements were as shown below in Table 3.

TABLE 3: WEATHER CONDITIONS DURING NOISE MONITORING					
Location	Date/Time	Max Wind Speed (m/s)	Wind Direction	Temperature	Precipitation
R3	12/06/2014 18:01 – 18:51	0.3	S	19°C	None
R15	12/06/2014 18:56 – 19:46	0.3	S	17°C	None

4.4 Commentary

The following observations of local noise sources were made whilst at the site during monitoring:

- At R3 (Savage Road) the noise climate was dominated by local road traffic noise on Savage Road (vehicles and motorbikes) and other surrounding roads (particularly Wolseley Road) as well as an unidentified hum both from HMNB, presumed to be from the ships. In addition there was also noise from passing trains; residents and pedestrians parking up and/or walking past; children playing in the play park on Savage Road; as well as bird song. No site noise was noticeable at the receptor.
- At R15 (Talbot Gardens) the noise climate was dominated by local road traffic noise on Savage Road (vehicles and motorbikes) and other surrounding roads (particularly Wolseley Road) as well as an unidentified hum both from HMNB, presumed to be from the ships. In addition there was also noise from passing trains; children playing in the play park on Savage Road; bird song. No site noise was noticeable at the receptor.

4.5 Results

The results of noise monitoring undertaken on 12th June 2014 are given below in Table 4.

The full noise survey data for both sites are provided in Appendix A, Tables A1 and A2.

TABLE 4: BASELINE NOISE LEVELS AND NOISE LIMITS FOR NDT

Location	Date & Time	NDT Noise Level L _{Aeq,50min} (dB)		NDT Noise Level L _{AFmax} (dB)	Baseline Noise Level L _{Aeq,4hr} (dB)		Noise Limits (based on façade measurement)	Difference between NDT Noise Level (L _{Aeq,50min}) and Baseline (L _{Aeq,4hr}) (dB)
		Free Field	Façade	Façade	Free Field	Façade	L _{Aeq,4hr} dB	
R3	12/06/2014 18:01 – 18:51	-	54	75	-	51	61	3
R15	12/06/2014 18:56 – 19:46	-	47	66	-	43	58	4

Noise levels recorded were within the Plymouth City Council's Code of Construction Practice noise limits for weekday evening work and within 5 dB of the baseline noise level. The L_{AFmax} events included in Table 4 were not a result of NDT testing, but instead due to off-site noises.

No site noises were recorded at either Savage Road or Talbot Gardens during the monitoring period, instead noise was dominated by road traffic and an unidentified hum from Her Majesty's Naval Base, presumed to be from the ships.

It was noted that there was a greater level of activity in the area, presumed to be a result of the warm and dry weather; in combination with the noise from HMNB, this could account for the higher noise level which was recorded.

Full monitoring results, complete with surveyor notes on the noise climate and extraneous noises, are recorded in Appendix A, Table A1 (Savage Road) and A2 (Talbot Gardens).

APPENDIX A: FULL NOISE MONITORING RESULTS

Tables A1 and A2 list the full suite of measured noise data.

TABLE A1: SAVAGE ROAD MEASURED NOISE LEVELS					
Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
12/06/2014 18:01	05:00.0	53.5	68	49.5	
12/06/2014 18:06	05:00.0	54.3	65.4	49.5	Car passing with loud music playing.
12/06/2014 18:11	05:00.0	53.1	65.9	48.5	Train; Car passing with loud music playing
12/06/2014 18:16	05:00.0	52.6	61.1	48.5	
12/06/2014 18:21	05:00.0	54.5	71.2	49.5	Numerous dogs barking in the distance; raised noises in the flat by the SLM.
12/06/2014 18:26	05:00.0	52.1	62.4	47.5	Train.
12/06/2014 18:31	05:00.0	52	63.2	48	
12/06/2014 18:36	05:00.0	52.5	62.2	49.5	Loudspeaker announcement in HMNB.
12/06/2014 18:41	05:00.0	51.6	62.8	48.5	
12/06/2014 18:46	05:00.0	56.5	75.3	48	Van passing below SLM loudly.

TABLE A2: TALBOT GARDENS MEASURED NOISE LEVELS

Date & Start time	Duration	L _{Aeq} (dB)	L _{AFmax} (dB)	L _{AF90} (dB)	Notes
12/06/2014 18:56	05:00.0	45.8	55.5	43	
12/06/2014 19:01	05:00.0	45.6	52.4	42.5	
12/06/2014 19:06	05:00.0	46.8	57.8	42	Train.
12/06/2014 19:11	05:00.0	46.2	57.1	42.5	Loudspeaker announcement in HMNB.
12/06/2014 19:16	05:00.0	45.7	54	42	
12/06/2014 19:21	05:00.0	47.9	63.5	42.5	
12/06/2014 19:26	05:00.0	50.8	66.1	44	
12/06/2014 19:31	05:00.0	47	55.6	43.5	
12/06/2014 19:36	05:00.0	48.5	62	43.5	
12/06/2014 19:41	05:00.0	47	63.3	43.5	